

C01 16.01.23 Plant Room, Server Room Layout Update. C00 14.12.22 | Construction Issue. T01 |14.10.22 | Entrance lobby updated OT/IR Fire Evacuation Key Rev Date Description Drawn/ Checked Escape Route Widths: In line with Sections 3.21 & 3.22 of 'Approved Document Part B, Volume 2 — buildings other than dwellinghouses' — the adjacent calculations provide justification for the clear opening widths for escape from each floor level/room in accordance with Table 4 & Appendix C. <u>Sprinklers</u> System design and installed in compliance with BS EN 12845:2015 & LPC Technical Bulletins Ipswich East Units 4-10, Hening Ave., Ipswich, IP3 9QJ Fire Evacuation Plan Existing wall to achieve min 30 minute fire rating (suitability of wall to be confirmed on site by Pure Ground Floor Plan Fire Alarm Fire Alarm designed and installed to BS 5839. Smoke & heat detection / emergency lighting by specialist. Please refer to SKI/PG Existing wall to achieve min 60 minute fire rating (suitability of wall to be confirmed on site by Pure Ground Floor Exit 1 is restricted by Exit 1A Clear Opening Width = 1050mm (allows 220 persons to escape, largest opening to be 1:100 @ A1 Escape Lighting Emergency escape lighted designed and installed in accordance with BS 5266: Part 1. Please refer to M&E Engineer's drawings for final layout and specification. discounted) Exit 2 Clear Opening Width = 1050mm (allows 220 persons to escape) Exit 3 Clear Opening Width = 1050mm (allows 220 persons to escape) Exit 4 Clear Opening Width = 800mm (allows 60 persons to escape) Exit 5 Clear Opening Width = 800mm (allows 60 persons to escape) CONSTRUCTION New wall to achieve min of 30min fire rating Pure Gym Ltd Town Centre House The Merrion Centre Escape Signage and emergency lighting is CDP under the M&E specification. Details of contractors proposals to be provided to Building Control Approved Inspector and Fire Officer within the Contractors Proposals Package, Clause 1.4 New wall to achieve min of 60min fire rating Total Aggregate Width for Floor (Less Largest Opening Width of 1050mm from Exit 1A = 3700mm Based on NIA of 7207sqft, the Puregym Average Peak occupancy target = 194 Persons Calculated using Puregym Fire Safety Occupancy Levels Forecast Tool. The designed occupancy of the unit as calculated would allow a max. No. of 560 persons to escape, which is larger than the total estimated occupancy capacity of 194 persons and is therfore thought to meet with the Approved Document Part B. Protected areas: walls, floors, ceilings and doors to achieve 60 minute fire resistant construction.

NOTE:

regulation requirements

Proposals must comply with all acoustic, fire & building

• No dimensions are to be scaled from this drawing. The

contractor is responsible for checking all dimensions on