

N.B

All building services to be inspected and commissioned in accordance with manufacturers' instructions, on completion of works

N.B. ALL FIRE DOORS WITHIN PROTECTED ZONE WALLS TO BE 60m FIRE RATING.

ALL FIRE DOORS TO BE ON MAG LOCKS LINKED TO THE FIRE ALARM TO FAIL SAFE. IN THE EVENT THAT THE ALARM IS RAISED ALL DOORS ARE RELEASED ALLOWING FOR FREE ESCAPE, INCLUDING ESCAPE DOORS FROM THE SECOND FLOOR OFFICE THROUGH THE GYM ACCOMODATION STAIR.

